



TEST CERTIFICATE
ISSUED BY SIRA TEST & CERTIFICATION LIMITED

**TEST FOR THE INGRESS PROTECTION OF
A DUPLO SIREN MOTOR ENCLOSURE**

Supplier: Klaxon Signals
Wrigley Street
Oldham
Lancashire
OL4 1HW

Model or Type Identification: Duplo Siren motor enclosure

Standard: BS EN 60529:1992 Incorporating Amendments Nos 1 and 2

Deviations from Standard: None

ST&C Test Procedure: LOP 220

ST&C Test Reports: 07/0330, N58D16501C, 07/0515 and N58D17159A

Sample Delivery Date: 23 May 2007 (for IPX5 testing)
28 August 2007 (for IP6X testing)

Test Conducted On: 25 May 2007 (IPX5 testing)
28 to 29 August 2007 (IP6X testing)

This certificate refers to the performance of the test sample when tested against the agreed programme. It does not imply that any other samples or products necessarily comply with the requirements of the test programme.

Sira Test & Certification Limited being a UKAS accredited Test House in accordance with ISO/IEC 17025 has tested the above Duplo Siren motor enclosure, and has found it to comply with the requirements of the Ingress Protection Code: IP 65.

S P Cork
Laboratory Manager

Dated 6 September 2007

This certificate may only be reproduced in its entirety and without change

Page 1 of 1

Certificate No: Sira 58D17159D
FORM 6240, Issue 8

a Volvere plc group company