



# sira

Hazardous Area Centre,  
Rake Lane, Ecclestone,  
Chester, CH4 9JN, England

## TEST CERTIFICATE

ISSUED BY SIRA TEST & CERTIFICATION LIMITED

Tel: +44 (0) 1244 670900  
Fax: +44 (0) 1244 681330  
Email: [exhazard@sira.co.uk](mailto:exhazard@sira.co.uk)  
Web: [www.siraservices.com](http://www.siraservices.com)

### TEST FOR THE INGRESS PROTECTION OF A SOUNDER/BEACON ENCLOSURE

<b>Manufacturer:</b>	Klaxon Signals Ltd Wrigley Street Oldham OL4 1HW
<b>Model or Type Identification:</b>	Sonos range of sounders/beacons
<b>Standard:</b>	BS EN 60529:1992 Inc Amendments Nos 1 and 2
<b>Deviations from Standard:</b>	None
<b>ST&amp;C Test Procedure:</b>	LOP 220
<b>ST&amp;C Test Report:</b>	05/0300
<b>Samples Delivery Dates:</b>	8 to 15 July 2005
<b>Tests Conducted Between:</b>	12 to 15 July 2005

This certificate refers to the performance of the test samples when tested against the agreed programme. It does not imply that any other samples or products necessarily comply with the requirements of the test programme.

Sira Test & Certification Limited being an UKAS accredited Test House in accordance with ISO/IEC 17025 certifies that the Sonos range of sounders/beacons have been found to comply with the requirements of the Ingress Protection Code: IP 65

**S P CORK**  
Technical Manager

Dated 15 July 2005

*This certificate may only be reproduced in its entirety and without change*

Page 1 of 1

**Certificate No: Sira 58D136817B**  
**FORM 5240, Issue 7**

**siragroup**