

Certificate of constancy of performance,

0832-CPR-F0008

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

**ESCA3000R and ESCA3000W
Conventional Type A sounder and ceiling mounted white light LED visual alarm devices**

(For full product details and conditions of use refer to appendix)

Produced by or for

Texecom Ltd

**Bradwood Court, St Crispin Way
Haslingden
Lancashire
BB4 4PW
United Kingdom**

and produced in the manufacturing plant(s)

Texecom Ltd

**Bradwood Court, St Crispin Way
Haslingden
Lancashire
BB4 4PW
United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 54-23:2010 - Visual alarm devices
EN 54-3:2001 + A1:2002 + A2:2006 - Sounders**

under system 1 are applied and that

the products fulfil all the prescribed requirements set out above.

This certificate was first issued on 02 October 2013 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Eman Mattie-Suleiman, Technical Development Director
On behalf of BRE Global Limited
Date of issue: 02 October 2013
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR- F0008

Bases:

PSO-0001 / 18-185856-2 – Red Shallow base
PSO-0017 / HSG6918 – Red Deep base
PSO-0006 / 18-186049-2 – White Shallow base
PSO-0018 / HSG6917 – White Deep base

Notes:

1. ESCA3000R – Red Body (clear lens + white light LED) Type A – use base PSO-0001 / 18-185856-2
2. ESCA3000R – Red Body (clear lens + white light LED) Type A – use base PSO-0017 / HSG6918
3. ESCA3000W – White Body (clear lens + white light LED) Type A – use base PSO-0006 / 18-186049-2
4. ESCA3000W – White Body (clear lens + white light LED) Type A – use base PSO-0018 / HSG6917
5. The sounder meets the requirements of EN 54-3:2001 at tones 1, 2, 3, 6, 7 & 13
6. All of the VADs meet the requirements of EN 54-23:2010 for the following;
 - Category C-3-15
 - Flash rates 0.5Hz and 1Hz
 - Synchronization



Eman Mattie-Suleiman, Technical Development Director
On behalf of BRE Global Limited
Date of issue: 02 October 2013
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.