

Construction Products Regulation (CPR)

Declaration of Performance

PRODUCT	TYPE	CPR REFERENCE	CERTIFICATE
Sonos			
Sonos Sounder Beacon LED	PSS-0068	0832-CPR-0297	Click Here > Page 2
Sonos Sounder	PSS-0084	0832-CPR-0298	Click Here > Page 3
Sounder Beacon LED (Common Operation)	PSS-0045	0832-CPR-0546	Click Here > Page 4
Base Sounder			
Base Sounder	PBS-0003	0832-CPR-0453	Click Here > Page 5
Fire Bell			
6" (150mm) Fire Bell	TAA-0007	0832-CPR-0760	Click Here > Page 6
8" (200mm) Fire Bell	TAA-0015	0832-CPR-0761	Click Here > Page 7
6" (150mm) Weatherproof Fire Bell	TAA-0017	0832-CPR-0959	Click Here > Page 8
8" (200mm) Weatherproof Fire Bell	TAA-0020	0832-CPR-0960	Click Here > Page 9
Nexus 105			
Nexus 105 Sounder Beacon LED	PNC-0024	0832-CPR-0615	Click Here > Page 10
Nexus 105 Sounder Beacon Xenon	PNC-0001	0832-CPR-0616	Click Here > Page 11
Nexus 105 Sounder	PNS-0001	0832-CPR-0617	Click Here > Page 12
Nexus 110			
Nexus 110 Sounder Beacon LED	PNC-0029	0832-CPR-0618	Click Here > Page 13
Nexus 110 Sounder Beacon Xenon	PNC-0013	0832-CPR-0619	Click Here > Page 14
Nexus 110 Sounder	PNS-0013	0832-CPR-0620	Click Here > Page 15
Nexus 120			
Nexus 120 Sounder Beacon LED	PNC-0035	0832-CPR-0621	Click Here > Page 16
Nexus 120 Sounder Beacon Xenon	PNC-0003	0832-CPR-0622	Click Here > Page 17
Nexus 120 Sounder	PNS-0005	0832-CPR-0623	Click Here > Page 18
Outdoor Sounder			
Outdoor Sounder Xtravert (Blank)	FDV-0226	0086-CPR-557583	Click Here > Page 19
Outdoor Sounder Xpro-V (Spanish)	FDV-0235	0086-CPR-557583	Click Here > Page 20
Outdoor Sounder Xpro-V (English)	FDV-0236	0086-CPR-557583	Click Here > Page 21
Outdoor Sounder Xpro-V (Portuguese)	FDV-0237	0086-CPR-557583	Click Here > Page 22
Outdoor Sounder Xtravert (Spanish)	FDV-0238	0086-CPR-557583	Click Here > Page 23
Outdoor Sounder Xpro-V (Italian)	FDV-0252	0086-CPR-557583	Click Here > Page 24

Declaration of Performance.

0832-CPR-0297


0832-CPD-0297

Product Type	PSS-0068; PSS-0079; PSS-0073; PSS-0080; PSS-0055		
Type	Sonos Conventional Sounder LED Strobe- Red/White		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0297		
Declared Performance			
Essential Characteristics	EN54-3 Subclause	Type A	Type B
Reproducibility	5.2	Pass	Pass
Operational performance	5.3	Pass	Pass
Durability	5.4	Pass	Pass
Dry Heat (operational)	5.5	Pass	Pass
Dry Heat (endurance)	5.6	Pass	Pass
Cold (operational)	5.7	Pass	Pass
Damp heat, cyclic (operational)	5.8	Pass	Pass
Damp heat, steady state (endurance)	5.9	N/A	Pass
Damp Heat, cyclic (endurance) (Only for deep base version)	5.10	Pass	Pass
SO2 corrosion (endurance)	5.11	Pass	Pass
Shock (operational)	5.12	Pass	Pass
Impact (operational)	5.13	Pass	Pass
Vibration (operational)	5.14	Pass	Pass
Vibration (endurance)	5.15	Pass	Pass
Electrostatic discharge (operational)	5.16	Pass	Pass
Radiated electromagnetic fields (operational)	5.16	Pass	Pass
Voltage transients, fast transient bursts (operational)	5.16	Pass	Pass
Enclosure Protection	5.17	Pass	Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0832-CPR-0298


0832-CPD-0298

Product Type	PSS-0084; PSS-0089		
Type	Sonos Conventional Sounder – Red/White		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0298		
Declared Performance			
Essential Characteristics	EN54-3 Subclause	Type A	Type B
Reproducibility	5.2	Pass	Pass
Operational performance	5.3	Pass	Pass
Durability	5.4	Pass	Pass
Dry Heat (operational)	5.5	Pass	Pass
Dry Heat (endurance)	5.6	Pass	Pass
Cold (operational)	5.7	Pass	Pass
Damp heat, cyclic (operational)	5.8	Pass	Pass
Damp heat, steady state (endurance)	5.9	N/A	Pass
Damp Heat, cyclic (endurance) (Only for deep base version)	5.10	Pass	Pass
SO2 corrosion (endurance)	5.11	Pass	Pass
Shock (operational)	5.12	Pass	Pass
Impact (operational)	5.13	Pass	Pass
Vibration (operational)	5.14	Pass	Pass
Vibration (endurance)	5.15	Pass	Pass
Electrostatic discharge (operational)	5.16	Pass	Pass
Radiated electromagnetic fields (operational)	5.16	Pass	Pass
Voltage transients, fast transient bursts (operational)	5.16	Pass	Pass
Enclosure Protection	5.17	Pass	Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0832-CPR-0546

0832-CPD-0546

Product Type	PSS-0045; PSC-0051; PSC-0062; PSC-0063		
Type	Sounder Beacon with LED Strobe Common Operation – Red/White		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0546		
Declared Performance			
Essential Characteristics	EN54-3 Subclause	Type A	Type B
Reproducibility	5.2	Pass	Pass
Operational performance	5.3	Pass	Pass
Durability	5.4	Pass	Pass
Dry Heat (operational)	5.5	Pass	Pass
Dry Heat (endurance)	5.6	Pass	Pass
Cold (operational)	5.7	Pass	Pass
Damp heat, cyclic (operational)	5.8	Pass	Pass
Damp heat, steady state (endurance)	5.9	Pass	Pass
Damp Heat, cyclic (endurance) (Only for deep base version)	5.10	N/A	Pass
SO2 corrosion (endurance)	5.11	Pass	Pass
Shock (operational)	5.12	Pass	Pass
Impact (operational)	5.13	Pass	Pass
Vibration (operational)	5.14	Pass	Pass
Vibration (endurance)	5.15	Pass	Pass
Electrostatic discharge (operational)	5.16	Pass	Pass
Radiated electromagnetic fields (operational)	5.16	Pass	Pass
Voltage transients, fast transient bursts (operational)	5.16	Pass	Pass
Enclosure Protection	5.17	Pass	Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date of issue: 20/06/2013

Declaration of Performance.

0832-CPR-0453


0832-CPD-0453

Product Type	PBS-0003		
Type	Universal Base Sounder – white – cream - red		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0453		
Declared Performance			
Essential Characteristics	EN54-3 Subclause	Type A	
Reproducibility	5.2	Pass	
Operational performance	5.3	Pass	
Durability	5.4	Pass	
Dry Heat (operational)	5.5	Pass	
Dry Heat (endurance)	5.6	Pass	
Cold (operational)	5.7	Pass	
Damp heat, cyclic (operational)	5.8	Pass	
Damp heat, steady state (endurance)	5.9	Pass	
SO2 corrosion (endurance)	5.11	Pass	
Shock (operational)	5.12	Pass	
Impact (operational)	5.13	Pass	
Vibration (operational)	5.14	Pass	
Vibration (endurance)	5.15	Pass	
Electrostatic discharge (operational)	5.16	Pass	
Radiated electromagnetic fields (operational)	5.16	Pass	
Voltage transients, fast transient bursts (operational)	5.16	Pass	
Enclosure Protection	5.17	Pass	

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue:

Declaration of Performance.

0832-CPR-0760

0832-CPD-0760

Product Type	TAA-0007		
Type	6" (150mm) indoor fire bell		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0760		
Declared Performance			
Essential Characteristics	EN54-3 Subclause	Type A	
Reproducibility	5.2	Pass	
Operational performance	5.3	Pass	
Durability	5.4	Pass	
Dry Heat (operational)	5.5	Pass	
Dry Heat (endurance)	5.6	Pass	
Cold (operational)	5.7	Pass	
Damp heat, cyclic (operational)	5.8	Pass	
Damp heat, steady state (endurance)	5.9	Pass	
SO2 corrosion (endurance)	5.11	Pass	
Shock (operational)	5.12	Pass	
Impact (operational)	5.13	Pass	
Vibration (operational)	5.14	Pass	
Vibration (endurance)	5.15	Pass	
Electrostatic discharge (operational)	5.16	Pass	
Radiated electromagnetic fields (operational)	5.16	Pass	
Voltage transients, fast transient bursts (operational)	5.16	Pass	
Enclosure Protection	5.17	Pass	

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue:

Declaration of Performance.

0832-CPR-0761


0832-CPD-0761

Product Type	TAA-0015		
Type	8" (200mm) indoor fire bell		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0761		
Declared Performance			
Essential Characteristics	EN54-3 Subclause	Type A	
Reproducibility	5.2	Pass	
Operational performance	5.3	Pass	
Durability	5.4	Pass	
Dry Heat (operational)	5.5	Pass	
Dry Heat (endurance)	5.6	Pass	
Cold (operational)	5.7	Pass	
Damp heat, cyclic (operational)	5.8	Pass	
Damp heat, steady state (endurance)	5.9	Pass	
SO2 corrosion (endurance)	5.11	Pass	
Shock (operational)	5.12	Pass	
Impact (operational)	5.13	Pass	
Vibration (operational)	5.14	Pass	
Vibration (endurance)	5.15	Pass	
Electrostatic discharge (operational)	5.16	Pass	
Radiated electromagnetic fields (operational)	5.16	Pass	
Voltage transients, fast transient bursts (operational)	5.16	Pass	
Enclosure Protection	5.17	Pass	

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue:

Declaration of Performance.

0832-CPR-0960


0832-CPD-0960

Product Type	TAA-0020		
Type	8" (200mm) Outdoor Fire Bell		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0960		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0832-CPR-0959


0832-CPD-0959

Product Type	TAA-0017		
Type	6" (150mm) outdoor fire bell		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0959		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0832-CPR-0615


0832-CPD-0615

Product Type	PNC-0024		
Type	Nexus 105 Conventional Sounder and LED Beacon		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0615		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0832-CPR-0616

0832-CPD-0616

Product Type	PNC-0001		
Type	Nexus 105 Conventional Sounder with Xenon Beacon		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0616		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0832-CPR-0617


0832-CPD-0617

Product Type	PNS-0001		
Type	Nexus 105 Conventional Sounder		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0617		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0832-CPR-0618


0832-CPD-0618

Product Type	PNC-0029		
Type	Nexus 110 Conventional Sounder with LED Beacon		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0618		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0832-CPR-0619


0832-CPD-0619

Product Type	PNC-0013		
Type	Nexus 110 Conventional Sounder with Xenon Beacon		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0619		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0832-CPR-0620


0832-CPD-0620

Product Type	PNS-0013		
Type	Nexus 110 Conventional Sounder		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0620		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0832-CPR-0621

0832-CPD-0621

Product Type	PNC-0035		
Type	Nexus 120 Conventional Sounder with LED Beacon		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0621		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0832-CPR-0622


0832-CPD-0622

Product Type	PNC-0003		
Type	Nexus 120 Conventional Sounder with Xenon Beacon		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0622		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0832-CPR-0623


0832-CPD-0623

Product Type	PNS-0005		
Type	Nexus 120 Conventional Sounder		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0578		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0623		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0086-CPR-557583

0086-CPD-557583

Product Type	FDV-0252		
Type	Type B Outdoor Sounder (Xpro-V Cover) Italian		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BSI		
Accreditation Number	0135		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0086-CPD-557583		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0086-CPR-557583


0086-CPD-557583

Product Type	FDV-0238		
Type	Type B Outdoor Sounder (Xtravert Cover) Spanish		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BSI		
Accreditation Number	0135		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0622		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0086-CPR-557583


0086-CPD-557583

Product Type	FDV-0237		
Type	Type B Outdoor Sounder (Xpro-V Cover) Portuguese		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BSI		
Accreditation Number	0135		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0086-CPD-557583		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0086-CPR-557583


0086-CPD-557583

Product Type	FDV-0236		
Type	Type B Outdoor Sounder (Xpro-V Cover) English		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BSI		
Accreditation Number	0135		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0086-CPD-557583		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0086-CPR-557583


0086-CPD-557583

Product Type	FDV-0235		
Type	Type B Outdoor Sounder (Xpro-V Cover) Spanish		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BSI		
Accreditation Number	0135		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0086-CPD-557583		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013

Declaration of Performance.

0086-CPR-557583

0086-CPD-557583

Product Type	FDV-0226		
Type	Type B Outdoor Sounder (Xtravert Cover) Blank		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
System of assessment	System 1		
Notified Body	BSI		
Accreditation Number	0135		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0622		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: James E Ludwig Function: Managing Director

Signature: 

Place and date if issue: 20/06/2013